



INSTALLATION NOTES:

1. ALL PLASTIC PIPE TO BE INSTALLED ACCORDING TO THESE DETAILS UNLESS OTHERWISE NOTED OR DETAILED.
2. THE PORTLAND CEMENT CONCRETE USED FOR THRUST BLOCKS SHALL BE 470-B-2000 CONCRETE.
3. ALL ANCHOR RODS SHALL BE GALVANIZED STEEL WITH MIN. OF 1/2" INCH IN DIAMETER (WRAPPED AROUND PIPE).
4. SIZE OF THRUST BLOCKS SHALL BE SPECIFIED IN THE CONTRACT DRAWINGS.
5. THESE THRUST BLOCKS SHALL BE USED FOR PLASTIC PIPES WITH 3" DIAMETER OR LARGER.

BUREAU OF ENGINEERING

DEPARTMENT OF PUBLIC WORKS

CITY OF LOS ANGELES

THRUST BLOCKS FOR PLASTIC PIPE LINE

**STANDARD PLAN
S-651-0**

SUBMITTED APRIL 21, 1976 <i>Robert H. Mass</i> DIVISION ENGINEER <i>Robert J. Brown</i> DEPUTY ENGINEER		REVISIONS				SUPERSEDES	REFERENCES
NO	DATE	DESCRIPTION	DIV. ENG'R.	CITY ENG'R.			
APPROVED JULY 12, 1976 <i>Donald C. Johnson</i> CITY ENGINEER						VAULT INDEX NUMBER B-3886	
DESIGNED BY	DRAWN BY	CHECKED BY					SHEET OF SHEETS
EMG	<i>Emmanuel</i>	K.S.S.					