

June, 1969

TABLE OF CONTENTS
STORM DRAIN STRUCTURES (G 600)

SECTION NO.	SUBJECT	DATE
G 601	Design Responsibility	June, 1969
G 602	Structural Criteria	"
G 610	CONDUITS	"
G 611	Applications	"
G 612	Configurations	"
G 613	Loading ant Bedding	"
G 620	STANDARD STRUCTURES	"
G 621	Manholes	"
G 622	Junctions	"
G 623	Transitions	"
G 624	Catch Basins	"
G 630	SPECIAL STRUCTURES	"
G 631	Inlet Structures	"
G 631.1	Geometric Design	"
G 632	Outlet Structures	"
G 632.1	Geometric Design	"
G 633	Energy Dissipator	"
G 634	Debris Basins	"
G 635	Subdrains	"
G 636	Flapgates	"
G 637	Street Culverts	"
G 638	Outlet Chambers	"
G 639	Small Curb Outlets	"
G 640	APPURTENANT CONSTRUCTION	"
G 641	Supports, Relocations, and Removals	"
G 642	Concrete Blankets and Encasements	"
G 643	Anchor Blocks and Thrust Blocks	"
G 644	Concrete Collars and Seals	"
G 645	Debris Barriers	"
G 646	Protection Barriers	"
G 647	Fences and Gates	"
G 648	Access Roads	"
G 649	Resurfacing and Remodeling	"

LIST OF FIGURES

NUMBER	TITLE	DATE
G 602	Depth-Load Relationship	June, 1969
G 612	Conveyance Factor--R.C. Pipe or Box	"
G 612A	Hydraulic Properties-C.M. Pipe Flowing Full	"
G 612B	Hydraulic Properties for Horseshoe Arch	"
G 613	D-Load for Case I Bedding of R C Pipe	"
G 613A	Gage Requirements for C.M. Pipe	"
G 613B	Pipes Under Railroad Tracks	"
G 621	Summary of Manhole and Junction Structures	"
G 622	Geometric Layout of Junctions	"
G 623	Summary of Transition Structures	"
G 623A	Geometric Design of High Velocity Expansions	"
G 623B	Geometric Design of High Velocity Contractions	"
G 623C	Graphs for Design of High Velocity Transitions	"
G 624	Street Reconstruction at Catch Basins	"
G 631	Typical Inlet Structures	"
G 632	Typical Outlet Structures	"
G 632A	Allowable Velocities for Erodible Linings	"
G 633	Impact Type Energy Dissipator	"
G 634	Debris Production Zones	"
G 634A	Debris Production Curves	"
G 635	Typical Subdrains	"
G 636	Automatic Flap Gate Inlets	"

Some of these are pipe to box, box to box, box to open channel, and open channel to open channel junctions. Junction Chamber No. 3 is used to join two or more small pipes in the parkway which require access. Special considerations must be given to high velocity flow junctions.

Increased structural dimensions or special design of junctions are necessary under the following conditions:

- (a) Where structures are subject to railroad loadings.
- (b) Where fills over structures are less than 1 foot or greater than 20 feet.
- (c) Where fills over structures are greater than 10 feet and at the same time the inverts or soffits of the main line and lateral join, or where the difference in elevation between them is less than 4 inches.
- (d) Where the outlet diameter of the junction structure exceeds 96 inches.
- (e) Where an inlet encroaches through the top slab.

Monolithic connections when required may be extended in length up to 4 feet to meet standard pipe lengths. (See standard plan Typical C.B., M.H. and J.C. No. 3 Monolithic Connection for R.C. Pipes 12" to 72" Inclusive and Subsection 3-31 of the standard plan Notice to Contractors-Comprehensive.) Only one Junction Structure B is permitted per pipe length (usually 8 feet). When a lateral inlet is greater than 39", a Junction Structure C shall be used. A Junction Structure C shall also be used where side inlets enter both sides of the conduit and an access shaft is not required. When side inlets enter both sides of a manhole, the manhole is lengthened as required so the access shaft is upstream of the inlets.

In designing a junction, the shortest practical structure that meets hydraulic and structural requirements should be determined. This is best accomplished by drawing a sketch of the relative positions of stub and main line to natural scale (usually 1" = 1.0') to determine the values called for on the standard plan. [Figure G 622](#) delineates the requirements and controls for design of junctions with pipe and box conduits. A manhole shaft is generally located upstream of inlets to provide clearance for steps.

The vertical alignment of the main line through a junction must have a minimum slope to maintain a 4 ft./sec. velocity. For a size increase downstream, soffits are joined. For a size decrease downstream, inverts are joined. The centerline of the side inlet is generally aligned to intersect the centerline of the main line. Steep inlets should not protrude into the manhole or Junction Structure top slab. To avoid this, the top slab may be thickened (see [Figure G 622](#), dimension Q) or the inlet grade may be broken at the location of elevation R, otherwise special structural design is required. For inlets into box structures or open channels, the inlet invert should not encroach into the side wall longitudinal or vertical construction joints.

Saddle connections in accordance with the Standard Plan shall not be used, except for private or roof drain connections of 10-inch diameter or less. The longitudinal axis of the connection shall intersect the longitudinal axis of the main line, and the entrance angle shall not be less than 70 degrees. The opening in the main line shall be core drilled using a drill the size of the connector pipe.

G 623 TRANSITIONS

A storm drain transition is a structure of varying cross-section designed to provide smooth flow between two conduits. A transition is usually required to change conduit size, to change type of conduit, or to avoid obstructions. For a transition with pipe conduits, standard manholes and junction structures are generally used. Special design is required for transitions with box, arch, or open channel conduits, or to join two different types conduits.

A transition must be hydraulically efficient yet practical to construct. The length of the transition is usually the prime consideration, as it ordinarily determines the cost. Straight-line connections are usually used on all transitions except on an expansion transition in free water surface high-velocity flow. For pipe or box conduits, soffits are joined for a size increase downstream and inverts are joined for size decrease downstream. For rectangular or trapezoidal channels, tops of walls or tops of side slopes are joined. A summary of

ging. It is therefore necessary for the designer to evaluate properly the requirements of each situation before starting design.

G 631.1 Geometric Design: The hydraulic and structural considerations shall dictate the geometry of an inlet structure. Where applicable, an inlet structure shall consist of a headwall to protect the conduit and embankment, wingwalls to direct the flow to the conduit, a drop inlet apron to accelerate the flow, and a rounded inlet to diminish head loss.

The location of the headwall in an embankment generally determines the height and width of the wall. The minimum height of headwall shall provide one foot of cover over the conduit, and should extend to the height of expected headwater. The minimum width of headwall without integral wingwalls shall be the width of the conduit plus 12 inches on each side. The headwall width may be extended to the existing banks of the watercourse. The top of the headwall should protrude 6 inches above the embankment slope.

Wingwalls may be either straight vertically or warped according to their application as shown on [Figure G 631](#). The length and height of wingwalls depend on the height of the headwall, the slope of the embankment, and the angle of horizontal flare. This angle of flare (a) is usually 45 degrees.

At inlets the smoothness of the joints between the headwall, wingwalls, and apron is an important hydraulic consideration. The inside surfaces of wingwalls and box conduit sidewalls as well as the apron and box conduit floor should join flush. For pipe conduits, the inside surface of wingwalls should be flush with the inside surface of the pipe at the springline. For small inlets, the apron should be warped to join the inside surface of the bottom half of the pipe. The inlet apron should extend at least one pipe diameter upstream of the conduit and should slope down toward the inlet a sufficient depth to maintain a safe headwater level. Pipe inlets shall have a 3-inch minimum radius. R.C. box inlets shall have a radius of 3 to 6 inches at the headwall face.

G 632 OUTLET STRUCTURES

Where a drain outlets into an improved storm drain or river, a conventional junction structure

or confluence is used. However, some drains discharge into City streets, the ocean, or unimproved watercourses. These are the outlets which require special design considerations.

The prime consideration in outletting a storm drain into a street is City liability. The designer shall check his design against the criteria given in Section G 012. For small flows, a culvert or a "burp" catch basin with bleeder line is adequate. For large flows or flows beyond street capacity, a storm drain system will probably be required.

Where a storm drain outlets directly into the ocean, the designer must consider tidal action, littoral drift, and saline conditions. Outlets to a harbor channel subject to backflow at high tide should be protected by a flapgate or overflow weir. The collection of sand from littoral drift at a beach outlet is difficult to predict and even more difficult to prevent. Outletting between high and low tide lines and the construction of a rock groin should reduce this problem. The use of Type V cement for concrete structures will prevent deterioration from salt water. If the outlet is located near a beach or public area, fencing and a protection barrier should be provided to prevent entrance into the conduit.

A common use of an outlet structure is to control the discharge of water in a natural watercourse. Precautions must be taken to avoid property damage. The best assurance against damage is to discharge the flow at all stages into the watercourse just as the former channel did. Since this is not always economical, good judgment must be used to determine the amount and type of protection that must be provided.

Erosion of the channel bed and banks is one of the designer's basic problems. If the velocity of discharge is greater than the normal velocity of the stream, the channel bed will erode. Eddy currents caused by an excessively rapid discharge will erode the channel banks. To prevent such erosion, the velocity must be decreased, the flow aligned and shaped to the natural channel, and the channel and conduit protected against scour.

Outlet structures are classified as either low or high velocity. A low velocity structure is one that can discharge water without the use of a special energy dissipator and not cause excessive erosion. This type of outlet structure is generally for sub-

critical outlet velocities. The two outlet structures shown on [Figure G 632](#) are typical for the types of channel shown thereon. These are intended only as a guide. Each outlet must be designed according to its requirements. Since experimental data are not available, the designer must predict the hydraulic behavior of each outlet structure designed.

The choice of an outlet that will assure reasonable control of the water must consider the following factors:

1. The quantity and velocity of conduit outlet flow.
2. The normal velocity of the existing channel downstream.
3. The vulnerability of the soil to erosion.
4. The adaptability of the structure to the location.
5. The simplicity of construction and low maintenance cost.

The existing channel "n" factors are selected from [Figure G 402](#). Allowable Velocities for Erodible Linings are given on [Figure G 632A](#). It is important that the existing channel conditions are properly evaluated and the "n" factor and lining chosen are consistent with those conditions. The best location for an outlet structure is generally one that requires the minimum amount of earthwork and erosion protection close to the location of the desired end of conduit.

When the outlet velocity is supercritical, the principal consideration is the dissipation of energy (see [Section G 633](#)).

G 632.1 Geometric Design: As with the inlet structure, the hydraulic and structural considerations shall dictate the geometric design of the outlet structure. It usually consists of an endwall, wingwalls, apron with cut-off wall, and bank protection. The size of the endwall is determined by the same considerations given in [Section G 631.1](#) for a headwall. The wingwalls are straight vertically with a horizontal flare angle (α) and length (L_A) as shown on [Figure G 632](#). The concrete apron should be at ground level and should terminate with a cut-off wall at least 2 feet deep. Wherever the bed or banks of an existing channel at the outlet are subject to erosion, they should be protected. See Example 6, Pages V-10 to V-18 of the ITTE Booklet, Street and Highway Drainage,

Volume I (1965) for different methods of channel protection and lining. Outlet flow conditions must be checked to assure that no hydraulic jump or other undesirable effect detrimental to the outlet can occur.

G 633 ENERGY DISSIPATORS

A high-velocity outlet is one which requires an energy dissipator to prevent excessive erosion or property damage. Means of dissipating energy at outlets are submergence, pool, hydraulic jump, and impact. A submerged outlet or plunge pool requires too large a structure to be economical under conditions encountered in the City. The control of a hydraulic jump at all stages of flow and the possible erosion resulting therefrom is also considered uneconomical for most City applications. Dissipation of energy by impact has the widest application by the City.

The Impact Type Energy Dissipator has been tested by the City Hydraulic Laboratory and is recommended for use with closed conduits. The geometric design is as indicated in [Figure G 633](#). The structural design is done by the Structural Engineering Division. The limit of use is given in Note 4 thereon. Other types of Stilling Basins and Energy Dissipators are given in the U.S. Department of Interior, Bureau of Reclamation Engineering Monograph No. 25, by A. J. Peterka. Whatever method is used to reduce velocity, the dissipation of energy must be contained within the confines of the structure for all stages of flow.-Failure to recognize a possible hydraulic jump or an area susceptible to excessive erosion may result in structural failure and property damage. The designer should consult his supervisor on the design of all major energy dissipators. Where values of Q and/or velocity exceed values in the Bureau of Reclamation Booklet, a model study should be made.

G 634 DEBRIS BASIN

A debris basin intercepts storm runoff debris at storm drain inlets located in the debris production zones given on [Figure G 634](#). A permanent debris basin consists of an earthfill embankment, outflow system, standpipe, trash barrier, and slope protection against erosion. The basin outflow system must pass the design storm runoff (as determined in Chapter G 200) without overtopping the embankments. The basin must provide a debris storage capacity as

determined by the Debris Production Curves shown on Figure G 634A. A source of information for the design of a debris basin can be obtained from the Bureau of Reclamation Book Design of Small Dams. The designer shall consult the state pamphlet for the determination of *Rules and Regulations Pertaining to Supervision of Dams in California*.

Before a debris basin is designed, the basin site must be selected. Sufficient right of way shall be provided for the full improvement of the debris basin and other area of debris settlement. Consideration may also have to be given to the temporary water storage area. An access road of adequate width must be provided to facilitate the removal and hauling of storm deposited debris. Debris racks or check dams should be used in watercourses with less than ten acres tributary in lieu of a debris basin.

Borings and soil analysis must be obtained for the debris basin area. Recommendations pertaining to all phases of work relating to soil mechanics on embankment and foundation engineering shall be requested from the Geology and Soils Engineering Section, Street Opening and Widening Division.

The debris basin capacity is calculated as the volume contained between the natural or graded ground and a plane extending upstream from the crest of the overflow spillway (or ogee storm drain inlet) at approximately 60% of the average original stream bed slope. Experience indicates that while the debris surface slope seldom exceeds 4% it may be as high as 8%. Extensive excavation below the level of the streambed should be avoided because of soil erosion. The application of the debris basin capacity computation should be approved by the Division/District Engineer because of wide variety of basin shapes and inflow conditions.

The debris basin dam is a compacted earthfill embankment with stable upstream and downstream slopes as recommended by the Geology and Soils Engineering Section. The fill embankment shall be designed safe against internal erosion from seepage flow, external erosion from overtopping or sloughing at seepage outlet, and excessive stresses upon the foundation for all conditions of operation. The upstream slope shall be

Paved with concrete extending 3 feet vertically below the bottom of the basin and 1 foot into the abutments as a deterrent to piping. The downstream slope shall be planted or otherwise protected from erosion. The crest of the embankment shall be 10 feet wide or wider if used as an access road to the basin and shall slope up from the spillway walls toward the abutments. The path of percolation can be critical and should be checked to prevent piping. The areas of contact between dam fills and abutments shall provide a minimum length of path of percolation, for maximum head differentials, on slopes of at least 8:1 (8=level length of path and 1 = head differential between ends of path).

The debris basin outflow system consists of a spillway and/or ogee type storm drain inlet and shall be designed for the peak flow of a 50-year storm. For a closed conduit outlet, an ogee type inlet as shown on plan D-19450 is recommended shall be designed for the peak flow of a 50-year (see Design of Small Dams). For an open channel outlet, a broad-crested weir ($C=2.80$) spillway is recommended. The minimum freeboard at the spillway crest shall be 3 feet.

An adequate bar rack (or grate) shall be provided upstream of the spillway and/or storm drain inlet to prevent clogging, especially when the outlet is a closed conduit (see Section G 645). The freeboard between the crest of embankment and water level shall be 3 feet.

A standpipe structure with holes and its outlet conduit to the outflow system conduit shall be provided to drain the water at all levels of the debris basin (see D-19450). The standpipe shall be located at the lowest point of the debris basin. The top of the structure shall be open end (with bar grate) and shall protrude at least one foot above the debris surface. The capacity of the standpipe and its outlet conduit shall be 20% of the 50-year peak flow. The standpipe holes shall provide this capacity for any six feet of standpipe height. The standpipe outlet conduit shall be designed for inlet control with a minimum grade of 5%. The alignment of standpipe outlet conduit shall not be located under the outlet system alignment.

Temporary debris basins are sometimes installed to meet situations that will exist for only a short time. They usually consist of an earthfill embank-

ment with a paved overflow spillway similar to the temporary desilting basin shown on [Figure G 154](#).

The removal of debris after every storm is required to continue effective protection of property downstream. Therefore, upon completion of construction of a debris basin, the designer shall notify the Sewer Maintenance Division of the Bureau of Sanitation so that proper maintenance can be scheduled.

G 635 SUBDRAINS

The most common applications of subdrains are under fill embankments and along storm drain conduits in watercourses. A standard subdrain usually consists of a filter blanket and perforated pipe (or equivalent) in a narrow trench backfilled with filter sand and drainage material. The types of conduits acceptable for use as subdrains are perforated pipes of corrugated metal (galvanized and asphalt coated), concrete, asbestos cement, vitrified clay, and a semicircular conduit of galvanized steel and corrugated metal cover. The material for filter blankets and other filters shall generally conform to the requirements shown on [Figure G 635](#).

An embankment subdrain is installed along the flow line of natural watercourse (or swale) and its tributaries under all fills. The minimum pipe size shall be 6" for lengths up to 500' and 8" for lengths exceeding 500'. The grade should not be flatter than 0.5%. Outlets into the storm drain conduit should be provided at intervals not exceeding 1000'. The subdrain should be laid with the perforations downward.

The use of subdrains along storm drain conduits shall be considered whenever test borings indicate the presence of groundwater. These subdrains increase the bearing capacity of the subgrade and decrease the hydrostatic pressure on the conduit. The basic considerations which determine subdrain requirements are the type of soil, type and location of the storm drain conduit, and groundwater conditions.

A distinction must be drawn between flow of free water as in sandy soils and capillary action as in clayey soils. When a storm drain is located where groundwater naturally concentrates, heavy flow should be anticipated and subdrain pipes are usually required (Conditions II and III, [Figure](#)

[G 635](#)). When a storm drain is located in wet clayey soil, which is practically non-percolating, weep holes in cast-in-place conduits or open joints in RC pipes are usually sufficient (Condition I, [Figure G 635](#)). A sand and gravel blanket is often used in a soft trench subgrade such as silt or clay which are moist from capillary action. To prevent blanket washout, cut-off walls with drainage outlets should be provided along the alignment. Additional soil testing and recommendations may be requested (if required) from the Geology and Soils Engineering Section, Street Opening and Widening Division.

Pipe subdrains may be slab or heel drains according to their location at the storm drain conduit. (see [Figure G 635](#)). These drains are 6" or 8" perforated pipes with the perforations downward. The subdrain is backfilled with a washed concrete sand filter 16" wide, extending from the base to the top of the storm drain conduit with a minimum depth of 2' below the ground surface to block surface drainage. The subdrains run parallel to the storm drain conduit in continuous reaches of 200 feet with a 3' gap separating the reaches. Branch outlets go into the storm drain conduit at 25' intervals or at closer intervals in areas of heavy groundwater flow. A slab drain with a low-flow channel is generally used where groundwater conditions are severe.

It may be more economical to consider groundwater pressures in the structural design of the storm drain conduit than to use subdrain pipes. This depends on the depth of cover over the storm drain conduit, its weight, and the elevation of the water table. When a storm drain conduit is too light to resist the uplift force of groundwater, which is often the case with a trapezoidal channel in a watercourse, subdrains must be used. The designer should consult the Structural Engineering Division to evaluate the structural design for groundwater conditions and weight to resist uplift.

G 636 FLAPGATES

A flapgate is a water-pressure-operated automatic gate that allows water outflow from a conduit but prevents backflow into the conduit. It is usually installed in a pipe or box outlet at which the water level is periodically higher than the area drained but allows drainage during other periods.

Whenever the designer considers using a flapgate, he must carefully investigate the actual conditions under which it must operate. Bronze seats and fittings should be used for flapgates subject to salt water. The operating head of water must be considered in selecting the proper flapgate. See the manufacturer's recommendations for the proper installation of flapgates.

A storm drain lateral which is flapgated into the main line must be set back from the main stream of flow for free operation of the flapgate. This requires a spur larger than the lateral in which to install the flapgate. Such an installation and its applications are given in [Figure G 636](#).

G 637 STREET CULVERTS

A street culvert is a shallow single- or multiple-barrel reinforced concrete box (or pipe) inletting and outletting through the curb. Its purpose is to convey street runoff underground across an intersection, thus making possible intersection design without cross-gutters. The culvert is also used to convey runoff under railroad tracks and to drain cul-de-sac streets and other locations where a shallow drainage structure is required. A street culvert is usually designed for low flow and as a temporary solution for a drainage problem until a storm drain is constructed.

A box culvert has a minimum height of 4" and a minimum inside width of 2'. The grade is whatever is attainable with a minimum grade of 0.002 feet per foot. The culvert location should be clear of surface and sub-surface obstructions. Street lights and traffic lights have location priority over culverts; therefore, the designer must coordinate his design with these departments. The culvert inlet should have a 9" curb face with a warped gutter. The culvert outlet should have an 8" curb face.

Culverts using small-diameter pipes are occasionally employed to keep dry-weather flow out of intersections. Pipe culverts may be gravity flow or inverted siphons, depending on the fall available across the intersection. These culverts are temporary construction and require more maintenance than normal.

All culverts must be cleaned periodically for proper operation. Therefore, upon completion of

Construction, the designer shall transmit a copy of the culvert plans to Sewer Maintenance Division, Bureau of Sanitation, thereby notifying them that maintenance should be scheduled.

G 638 OUTLET CHAMBERS

An outlet chamber conveys flow from a bench drain or lot drain, through the sidewalk or parkway area into the street gutter. The standard plan Outlet Chamber No. 4 is typical of single or multiple box sections of 4' width or less. The reinforced concrete top slab of the outlet chamber may be replaced with a removable galvanized diamond steel plate as per Standard Plan Sidewalk Culvert-Steel Plate Top to increase the depth of the structure.

An outlet chamber should have a minimum cross-sectional area equal to the inletting conduit. The minimum grade of the outlet chamber shall be 0.002 feet per foot. The maximum allowable outlet velocity shall be 7 ft./sec. to avoid cross-street flow. The outlet should have a 30° to 60° angle from the curb line facing downstream to prevent deposits of silt and debris in the street. The standard curb face at the outlet is 8"

G 639 SMALL CURB OUTLETS

A small curb outlet is one which conveys runoff from a private roof or surface area through the parkway and curb into the street gutter. The drain usually consists of acceptable 4" pipe or rectangular conduit. Since this drain is intended for small areas, only two pipes or equivalent conduit per outlet should be allowed. A large area should use outlet chambers. Loading conditions (particularly under driveways) must be considered. No open channel shall be allowed through a curb in an improved street area.

Small curb outlets must not be removed or plugged by storm drain construction. Those which interfere must be relocated or connected to the storm drain. It is generally preferable to outlet a reconstructed curb outlet into a catch basin whenever feasible. (See Sections 2-14 and 3-7 of Standard Plan Notice to *Contractors-Comprehensive*.)

G 640 APPURTENANT CONSTRUCTION

**G 641 SUPPORTS, RELOCATIONS, AND
REMOVALS**

Every effort is made in selecting a storm drain alignment to avoid substructures; therefore, those substructures still interfering must be either relocated or removed. An economic study should be made of those substructures within the trench and other substructures parallel to and one foot or less clear of the trench to determine if they should be relocated or supported. Whenever it is practical, any parallel substructure which has had its lateral support removed by the trench should be supported in place. (See Section 3-20 of Standard Plan Notice to Contractors-Comprehensive.) The interfering portions of abandoned sewers and storm drains are removed and sealed as per Subsection 306-3.1 of the Standard Specifications. For ownership and responsibility of relocating utilities, see Subsection G 364.1. For the method of removal and relocation of utilities, see Section 5 of the Standard Specifications.

Existing sewer and storm drain pipes across trenches shall be supported in accordance with the standard plan Supporting Pipes Across Trenches. Interfering sewer house connections shall be remodeled in accordance with the standard plan *Remodeling Details for House Connection Sewers*.

**G 642 CONCRETE BLANKETS AND
ENCASEMENTS**

Concrete blankets and encasements are usually used to protect existing sewer pipes from damage during construction and from surcharge loading. Existing storm drain pipes (or boxes) must be reviewed and designed by the Structural Engineering Division for additional protection (if required) from a change in loading either from a reduction in cover by grading, an increase in cover by fill, or lack of clearance for proper bedding of the proposed storm drain conduit.

The storm drain designer is responsible for transmitting the proposed plans to the Structural Engineering Divisions (or sections) for review and design (see Section G 362). To this end, a sewer pipe shall

Require review and protection whenever it lies within 18" below a proposed storm drain conduit. A concrete blanket as per Standard Plan is usually used over the sewer pipe for clearances of 6" to 18" below the proposed storm drain conduit. For clearances of less than 6" below or above the proposed storm drain conduit, a concrete encasement as per Standard Plan is generally used.

**G 643 ANCHOR BLOCKS AND
THRUST BLOCKS**

Anchor blocks are used to stabilize pipes on slopes of 3:1 or steeper in accordance with the standard plan Concrete Pipe Anchors. Manholes or similar concrete structures on steep slopes are sufficient to replace one anchor block per structure. Corrugated metal pipe on slopes of 3:1 or steeper may be anchored with steel stakes (approximately 6' long) or corrugated metal bulkheads (metal seep rings-see [Figure G 154](#)).

Whenever a force main under pressure changes direction, a thrust is exerted by the pipe against the soil which may be beyond its bearing capacity. To prevent pipe failure from this thrust, a concrete thrust block is constructed between the undisturbed trench and the pipe, thus increasing the pipe bearing area to the capacity the soil can bear. For force mains of 10" or larger operating under a pressure of 15 psi (35 feet of head) or higher, the designer shall refer the design of thrust blocks to the Structural Engineering Division.

G 644 CONCRETE COLLARS AND SEALS

A concrete collar is an expedient which should be used during construction only. A concrete collar should not be used in design or construction whenever beveled pipe and pulled joints can be used. However, concrete collars are required to connect pipes of different sizes or types or where the joint opening exceeds 3/4" for pipes 36" or less in diameter and exceeds 1" for pipes 39" or more in diameter. Concrete collars shall be constructed in accordance with the standard plan Concrete Collar for pipes 66" or less in diameter. Special design is required for concrete collars for pipes of larger diameter.

Whenever an existing pipe is removed or a new pipe is stubbed for future use, the open portion of the pipe must be sealed. For pipe or box conduits with the largest internal dimension of 4' or less, the conduit shall be sealed with an 8" wall of brick and mortar or a 6" concrete wall. For larger openings, special design is required. For the abandonment and sealing of catch basins, manholes, or other structures, see Subsection 306-3 of the Standard Specifications.

G 645 DEBRIS BARRIERS

When designing storm drain inlets in natural watercourses or other undeveloped areas, the designer must consider the problem of debris to assure the proper operation of the inlet. It is neither desirable nor economical to design drains which would pass all the debris; therefore, the debris must be controlled to avoid congestion or even plugging. The cost of damage from flooding which would result from lack of debris control amply justifies the design of adequate debris barriers

The basic kinds of stream burden debris found in this area are floating debris, flowing debris, and detritus. Floating debris consists of limbs, sticks, tumbleweeds, tules, refuse, etc. Flowing debris consists of a mixed fluid mass of fine soils, gravel refuse, etc. Detritus is a bed-load of sand, gravel, and rocks which tend to deposit with a reduction of velocity. Any or all of the above in varying amounts may be found in most watercourses.

The designer should conduct field investigations and evaluate his findings before selecting the type of debris barrier required, if any. Things to look for in the field are the type and amount of loose debris, the type of soil and its susceptibility to erosion, the expected amount and velocity of flow from the natural watercourse, the characteristics of the proposed inlet location, and the probable damage resulting from a partial or total inlet plugging.

The following are situations which may require a debris barrier. The amount and type of debris allowed to pass into the storm drain may be restricted by outlet requirements such as outlets into the street or on a beach area. If a pipe size is decreased downstream of the inlet, the smaller

pipe should determine the bar spacing of the debris rack. A decrease in conduit velocity can choke the drain with resulting detritus deposits. An impact type velocity breaker may be impaired by clogged debris.

Debris barriers that have been used effectively in the past are the debris rack, bar grate, debris riser, check dam, pipe and wire revetment, and debris basin (see [Section G 634](#)). The debris rack is a line of steel posts or rails spaced at intervals of 12 to 18 inches and placed across the channel upstream of the inlet. It is used to trap floating debris. The bar grate is usually a steel grate of bars inclined from the vertical and placed directly across the inlet to trap floating debris. The debris riser is a vertical pipe open at the top (or with a bar grate) with evenly spaced perforations all around its full height. It is used to trap the flowing debris or mud, for which on-site storage must be provided. It is extended as required according to the height of debris deposits. The check dam is a shallow barrier across the channel upstream of the inlet. A series of check dams, spaced far enough apart to effect a series of fan-shaped steps of alluvial deposits, is used to slow down the stream flow and trap the detritus. For a light amount of all three types of debris, a chain link fence check dam may be used. A pipe and wire revetment filled with brush is also effectively used across natural channels to trap debris and form a basin. However, for a large amount of eroded soil, such as a major watercourse in a hillside area, a permanent debris basin as given in [Section G 634](#) should be provided.

Debris barriers and basins require periodic cleaning and maintenance. Upon completion of construction of debris barriers (or basins), the designer shall notify the Sewer Maintenance Division of the Bureau of Sanitation, so proper maintenance can be scheduled.

G 646 PROTECTION BARRIERS

A protection barrier is a means of preventing people from entering storm drains. This protects the City from liability suits. The barrier may consist of chain link fencing around an inlet or outlet or a grate across the conduit entrance or outlet. A protection barrier is required whenever the inlet or outlet is an attractive nuisance or a

particularly hazardous situation. An inlet in a residential area or an outlet near a public beach should be considered a nuisance attractive to minors. A pipe inlet on a steep grade or an outlet inundated by the tide is particularly hazardous.

The type of protection barrier used depends on the size of the inlet or outlet structure and its location. For large closed conduits subject to plugging by debris, the breakaway grate shown in the LACFCD standard drawing Protection Barrier is recommended. For open channels that accept flow from the street or from a natural watercourse containing debris, a breakaway fence is suggested. For smaller conduits, a removable grate of vertical bars spaced at a maximum clear opening of 7" across the inlet or outlet is satisfactory.

G 647 FENCES AND GATES

Fences and fence gates utilized with storm drain projects shall be chain link in accordance with the Standard Specifications. Fencing shall generally be required at the perimeter of rights of way for open channels, drainage basins, pump stations, or any other surface installations deemed hazardous to the public. Fencing is also required at headwalls and endwalls, rectangular channel sidewalls, or other hazardous vertical drops.

Right of way fencing shall be 6 feet high with its centerline normally located 6' inside the right of way line. Top of wall fencing shall be 4 or 5 feet high with a right of way fence installation and 6 feet high without one. When there is an access road on one side (as shown in [Figure G 122](#)), the top of sidewall fence shall be installed on the access road side of the channel only.

Gates shall be installed wherever access is required for maintenance personnel and vehicles. Gates shall be the same height as the adjoining fencing. Personnel gates shall have a minimum width of 3 feet and vehicle gates a minimum width of 10 feet. An opened gate shall not protrude into a roadway or sidewalk area where traffic may be impeded or made hazardous.

G 648 ACCESS ROADS

Access roads provide vehicular access to drainage structures for maintenance or operation by City personnel. An access road shall have a mini-

mum width of 12 feet, and shall provide either a turn-around or access from both ends of the road. The roadway shall consist of a minimum of 4-inch select material surface (or equivalent) for grades up to 10%, and a minimum of 4-inch AC pavement for grades of 10% or greater. The maximum grade shall be 15%. The turn-around shall consist of either a cul-de-sac with a minimum radius of 30 feet or a "T" equivalent to the minimum alley turning area shown in the standard plan Standard Street Cross Sections. Access roads should be located in a right of way and be completely fenced (see [Figure G 122](#)). A soil sterilant should be used on the roadway to abate weed growth.

G 649 RESURFACING AND REMODELING

Whenever storm drains are constructed in City streets, the street improvements must be restored to their former state of usefulness. Pavement removed for the construction of storm drain conduits, warped gutters, or other drainage structures shall generally be replaced in kind (including the base) and thickness with a minimum thickness of 4" (see Subsection 306-1.12 of the Standard Specifications, and [Figure G 624](#)). A Resurfacing Schedule is shown on the title sheet of the construction plans (see section G 722). Trench resurfacing for pipe conduits is included in the cost of the pipe in place.

Generally most remodeling with storm drain work is done on catch basins and gutters. (For remodeling of existing drainage facilities, see Section G 123.) The extent of remodeling should be limited to what is required for proper drainage consistent with design standards and criteria.

Remodeling of street improvements in conjunction with storm drain work must be coordinated with the street design section or Division. If the remodeling is done with a drainage project, the designer prepares a sketch (indicating the location of the drainage project and the street remodeling) and requests the required street details for the most economical solution to the drainage problem, such as grade change or installation of a catch basin. If the remodeling is done with a street project, the designer checks that the drainage facilities conform to the latest standards, such as catch basin top slab and inlets, protection bars, curb height, grating spacing, etc.